

Project Goal
Client
Location
Project
Flood Reports

Various

Various

6072	Hawera Road Kohimarama Auckland	<ul style="list-style-type: none"> • Calculated overland flow paths to be kept clear at all times. • Calculated floor level and additional 500mm free board above flood level.
5879	Tuarangi Road Grey Lynn Auckland	<ul style="list-style-type: none"> • Calculated minimum floor levels 500mm above the calculated flood level. • Potential flooding at the rear of the site; recommended to take this into account with future development within the site.
5613	Rawhiti Road Onehunga Auckland	<ul style="list-style-type: none"> • Risk of flooding from overland flow and the effects on the proposed garage to overland flow. • Calculated level of proposed garage to be set 300mm above existing ground level.
5943	Wedgewood Avenue Mangere Auckland	<ul style="list-style-type: none"> • Confirmation that proposed development is at minimal risk of flooding • Calculations for finished floor level to be at RL 10.40m

